

# Suggested Specifications

- The main switch and branch switches shall be of the fusible bolted pressure type of ampacity as shown on the drawings. Switches shall be dead front, and equipped with Quick Make-Quick Break tease proof operators. An insulated bar will be used to connect the operator to the cross-bar, in order to keep ground potential out of the arcing zone. The operating handle shall have provisions for padlocking in open position with at least three padlocks.
- Face barriers when employed must be transparent to allow visible blades. Optional viewing windows may be provided in enclosure front.
- All switches must have UL labels, and be marked suitable for use on a circuit capable of delivering 200,000 RMS symmetrical amperes.
- All bolted pressure contact switches shall be manufactured by BOLTSWITCH, INC., of Crystal Lake, Illinois.

*boltswitch, inc.*