



VENTILATION

WHEN THE SWITCH IS TOTALLY ENCLOSED, VENTILATING LOUVERS MUST BE PROVIDED YIELDING A MINIMUM OPEN AREA OF "D" SQUARE INCHES NEAR THE TOP OF THE ENCLOSURE, AND "D" SQUARE INCHES NEAR THE BOTTOM OF THE ENCLOSURE.

OPERATOR DETAILS

FOR OPERATOR DETAILS AND ALTERNATE FRONT
CUT-OUTS, REFER TO DWG NO. O-1090A

KEY INTERLOCK

KEY INTERLOCK SPECIFICATIONS FOR SWITCHES
EQUIPPED WITH KEY INTERLOCK PROVISIONS ARE:

- .375 BOLT PROJECTION WHEN WITHDRAWN
- KIRK TYPE B
- SUPERIOR TYPE B6003



SECTION A-A

[illegible]

SERIES SLB SWITCHES WITH
INTEGRAL GROUND FAULT AND ARC FLASH

SCALE:	APPROVED BY:	DRAWN BY AG
DATE: 04/25/25		REVISED

boltswitch, inc.
CRYSTAL LAKE, ILLINOIS 60014

DRAWING NUMBER	0-1330A
----------------	---------